



# BULK WATER STATION

Located at: 700 9 Avenue North

If you experience difficulties or need to report a problem, please call Operational Services at 403.337.3446

---

## **\*DO NOT USE PUMPS TO PULL WATER FROM THE BULK WATER STATION\***

Our bulk water station requires a 3" male cam-lock and fill hose capable of handling 80 psi of pressure with sufficient length to reach from your vehicle to the cam-lock adaptor.

### **FILLING INSTRUCTIONS:**

1. Shut off your vehicles engine and pumps before filling the tank.
2. Using clean hands/gloves, connect 3" male cam lock fitting on fill hose to bulk water station.
3. Connect the other end of the fill hose to transport vehicle. **\*DO NOT HOLD FILL HOSE WHEN FILLING FROM BULK WATER STATION – INJURY MAY OCCUR\***.
4. Ensure all fill valves are open on transport vehicle.
5. Enter your pin code into keypad on bulk water station and press **ENTER**.
6. Enter required load in litres, then press **ENTER** button to confirm.
7. To stop the filling process at any time, push and hold the red stop button.
8. Ensure water flow has completely stopped prior to hose disconnection.
9. Disconnect all hoses and fittings from bulk water station.
10. Close door to keypad when finished.

---

\*Please note: The Town of Carstairs is not responsible for the quality of water once it leaves the bulk water station.